

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 3)**

Water Level of the accumulated water (at 7:00 on May 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,970 mm (5 mm increase since 7:00 on May 2)	O.P.+ 1,766 mm (1 mm decrease since 7:00 on May 2)	—
	Water level of Turbine Building	O.P.+ 2,351 mm (14 mm increase since 7:00 on May 2)	O.P.+ 2,766 mm (18 mm decrease since 7:00 on May 2)	O.P.+ 2,790 mm (37 mm decrease since 7:00 on May 2)	O.P.+ 2,794 mm (8 mm decrease since 7:00 on May 2)
	Water level of Reactor Building	O.P.+ 4,606 mm (11 mm increase since 7:00 on May 2)	O.P.+ 2,873 mm (10 mm decrease since 7:00 on May 2)	O.P.+ 2,823 mm (45 mm decrease since 7:00 on May 2)	O.P.+ 2,783 mm (6 mm decrease since 7:00 on May 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,482 mm (Increase from initial level:5,699 mm, 57 mm increase since 7:00 on May 2) O.P.+ 2,877 mm (Increase from initial level:3,603 mm, 452 mm increase since 7:00 on May 2) O.P.+ 4,317 mm (Water level from floor:521 mm, 147 mm decrease since 7:00 on May 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:35 on May 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:35 on May 1)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:22 on April 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes	※ From 9:58 AM to 2:53 PM on May 2nd, transfer of accumulated water from On-site Bunker to Process Main building was conducted.				

※ For quick publication of the data of water level, values are provided as reference values.