

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 4)**

Water Level of the accumulated water (at 7:00 on May 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,975 mm (5 mm increase since 7:00 on May 3)	O.P.+ 1,764 mm (2 mm decrease since 7:00 on May 3)	—
	Water level of Turbine Building	O.P.+ 2,362 mm (11 mm increase since 7:00 on May 3)	O.P.+ 2,755 mm (11 mm decrease since 7:00 on May 3)	O.P.+ 2,760 mm (30 mm decrease since 7:00 on May 3)	O.P.+ 2,780 mm (14 mm decrease since 7:00 on May 3)
	Water level of Reactor Building	O.P.+ 4,599 mm (7 mm decrease since 7:00 on May 3)	O.P.+ 2,867 mm (6 mm decrease since 7:00 on May 3)	O.P.+ 2,786 mm (37 mm decrease since 7:00 on May 3)	O.P.+ 2,773 mm (10 mm decrease since 7:00 on May 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,484 mm (Increase from initial level:5,701 mm, 2 mm increase since 7:00 on May 3) O.P.+ 3,467 mm (Increase from initial level:4,193 mm, 590 mm increase since 7:00 on May 3) O.P.+ 4,317 mm (Water level from floor:521 mm, No change since 7:00 on May 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:35 on May 1)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:35 on May 1)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:22 on April 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.