

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 5)**

Water Level of the accumulated water (at 7:00 on May 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,980 mm (5 mm increase since 7:00 on May 4)	O.P.+ 1,763 mm (1 mm decrease since 7:00 on May 4)	—
	Water level of Turbine Building	O.P.+ 2,375 mm (13 mm increase since 7:00 on May 4)	O.P.+ 2,720 mm (35 mm decrease since 7:00 on May 4)	O.P.+ 2,875 mm (115 mm increase since 7:00 on May 4)	O.P.+ 2,779 mm (1 mm decrease since 7:00 on May 4)
	Water level of Reactor Building	O.P.+ 4,589 mm (10 mm decrease since 7:00 on May 4)	O.P.+ 2,848 mm (19 mm decrease since 7:00 on May 4)	O.P.+ 2,913 mm (127 mm increase since 7:00 on May 4)	O.P.+ 2,770 mm (3 mm decrease since 7:00 on May 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,487 mm (Increase from initial level:5,704 mm, 3 mm increase since 7:00 on May 4) O.P.+ 2,932 mm (Increase from initial level:3,658 mm, 535 mm decrease since 7:00 on May 4) O.P.+ 4,321 mm (Water level from floor:525 mm, 4 mm increase since 7:00 on May 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:10 on May 4)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 12:35 on May 1 to 9:51 on May 4)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:22 on April 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.