

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 7)**

| | | | | | |
|---|--|---|---|--|--|
| Water Level of the accumulated water (at 7:00 on May 7) | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | Water level of Vertical Shaft | Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm) | O.P.+ 1,986 mm (4 mm increase since 7:00 on May 6) | O.P.+ 1,762 mm (No change since 7:00 on May 6) | — |
| | Water level of Turbine Building | O.P.+ 2,397 mm (11 mm increase since 7:00 on May 6) | O.P.+ 2,857 mm (72 mm increase since 7:00 on May 6) | O.P.+ 2,909 mm (14 mm increase since 7:00 on May 6) | O.P.+ 2,817 mm (18 mm increase since 7:00 on May 6) |
| | Water level of Reactor Building | O.P.+ 4,584 mm (3 mm increase since 7:00 on May 6) | O.P.+ 2,929 mm (69 mm increase since 7:00 on May 6) | O.P.+ 2,957 mm (13 mm increase since 7:00 on May 6) | O.P.+ 2,796 mm (13 mm increase since 7:00 on May 6) |
| | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building High Temperature Incinerator Building On-site Bunker Building | O.P.+ 4,492 mm (Increase from initial level:5,709 mm, 2 mm increase since 7:00 on May 6) O.P.+ 1,870 mm (Increase from initial level:2,596 mm, 521 mm decrease since 7:00 on May 6) O.P.+ 4,323 mm (Water level from floor:527 mm, 1 mm increase since 7:00 on May 6) | | |
| Situation of transfer of the accumulated water | | Unit 1 | Unit 2 | Unit 3 | Unit 4 |
| | | — | — | — | — |
| | | Unit 5 and 6 | | | |
| | | — | | | |
| Operation condition of water treatment facility | | Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:22 on April 30 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance | | | |
| Notes | | | | | |

※ For quick publication of the data of water level, values are provided as reference values.