

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 8)**

Water Level of the accumulated water (at 7:00 on May 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,989 mm (3 mm increase since 7:00 on May 7)	O.P.+ 1,761 mm (1 mm decrease since 7:00 on May 7)	—
	Water level of Turbine Building	O.P.+ 2,404 mm (7 mm increase since 7:00 on May 7)	O.P.+ 2,853 mm (4 mm decrease since 7:00 on May 7)	O.P.+ 2,866 mm (43 mm decrease since 7:00 on May 7)	O.P.+ 2,828 mm (11 mm increase since 7:00 on May 7)
	Water level of Reactor Building	O.P.+ 4,592 mm (8 mm increase since 7:00 on May 7)	O.P.+ 2,956 mm (27 mm increase since 7:00 on May 7)	O.P.+ 2,915 mm (42 mm decrease since 7:00 on May 7)	O.P.+ 2,807 mm (11 mm increase since 7:00 on May 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,498 mm (Increase from initial level:5,715 mm, 6 mm increase since 7:00 on May 7) O.P.+ 2,187 mm (Increase from initial level:2,913 mm, 317 mm increase since 7:00 on May 7) O.P.+ 4,324 mm (Water level from floor:528 mm, 1 mm increase since 7:00 on May 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:14 on May 7)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 12:20 on May 7)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on May 7 to 15:00 on May 7)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on May 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.