

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 10)**

Water Level of the accumulated water (at 7:00 on May 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,996 mm (5 mm increase since 7:00 on May 9)	O.P.+ 1,759 mm (1 mm decrease since 7:00 on May 9)	—
	Water level of Turbine Building	O.P.+ 2,424 mm (9 mm increase since 7:00 on May 9)	O.P.+ 2,900 mm (63 mm increase since 7:00 on May 9)	O.P.+ 2,859 mm (33 mm increase since 7:00 on May 9)	O.P.+ 2,816 mm (5 mm decrease since 7:00 on May 9)
	Water level of Reactor Building	O.P.+ 4,606 mm (9 mm increase since 7:00 on May 9)	O.P.+ 2,976 mm (33 mm increase since 7:00 on May 9)	O.P.+ 2,895 mm (32 mm increase since 7:00 on May 9)	O.P.+ 2,804 mm (4 mm decrease since 7:00 on May 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,508 mm (Increase from initial level:5,725 mm, 4 mm increase since 7:00 on May 9) O.P.+ 2,206 mm (Increase from initial level:2,932 mm, 389 mm decrease since 7:00 on May 9) O.P.+ 4,326 mm (Water level from floor:530 mm, No change since 7:00 on May 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 12:14 on May 7 to 10:02 on May 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 12:20 on May 7 to 10:51 on May 9)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on May 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.