

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 11)**

Water Level of the accumulated water (at 7:00 on May 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,997 mm (1 mm increase since 7:00 on May 10)	O.P.+ 1,757 mm (2 mm decrease since 7:00 on May 10)	—
	Water level of Turbine Building	O.P.+ 2,433 mm (9 mm increase since 7:00 on May 10)	O.P.+ 2,967 mm (67 mm increase since 7:00 on May 10)	O.P.+ 2,883 mm (24 mm increase since 7:00 on May 10)	O.P.+ 2,823 mm (7 mm increase since 7:00 on May 10)
	Water level of Reactor Building	O.P.+ 4,616 mm (10 mm increase since 7:00 on May 10)	O.P.+ 3,043 mm (67 mm increase since 7:00 on May 10)	O.P.+ 2,926 mm (31 mm increase since 7:00 on May 10)	O.P.+ 2,809 mm (5 mm increase since 7:00 on May 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,510 mm (Increase from initial level:5,727 mm, 2 mm increase since 7:00 on May 10) O.P.+ 1,662 mm (Increase from initial level:2,388 mm, 544 mm decrease since 7:00 on May 10) O.P.+ 4,327 mm (Water level from floor:531 mm, 1 mm increase since 7:00 on May 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	—	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on May 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.