

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 12)**

Water Level of the accumulated water (at 7:00 on May 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,001 mm (4 mm increase since 7:00 on May 11)	O.P.+ 1,757 mm (No change since 7:00 on May 11)	—
	Water level of Turbine Building	O.P.+ 2,440 mm (7 mm increase since 7:00 on May 11)	O.P.+ 2,961 mm (6 mm decrease since 7:00 on May 11)	O.P.+ 2,864 mm (19 mm decrease since 7:00 on May 11)	O.P.+ 2,831 mm (8 mm increase since 7:00 on May 11)
	Water level of Reactor Building	O.P.+ 4,631 mm (15 mm increase since 7:00 on May 11)	O.P.+ 3,069 mm (26 mm increase since 7:00 on May 11)	O.P.+ 2,912 mm (14 mm decrease since 7:00 on May 11)	O.P.+ 2,817 mm (8 mm increase since 7:00 on May 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,519 mm (Increase from initial level:5,736 mm, 9 mm increase since 7:00 on May 11) O.P.+ 1,772 mm (Increase from initial level:2,498 mm, 110 mm increase since 7:00 on May 11) O.P.+ 4,328 mm (Water level from floor:532 mm, 1 mm increase since 7:00 on May 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:32 on May 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:38 on May 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on May 11 to 15:00 on May 11)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on May 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.