

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 13)**

Water Level of the accumulated water (at 7:00 on May 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,006 mm (5 mm increase since 7:00 on May 12)	O.P.+ 1,761 mm (4 mm increase since 7:00 on May 12)	—
	Water level of Turbine Building	O.P.+ 2,346 mm (94 mm decrease since 7:00 on May 12)	O.P.+ 2,941 mm (20 mm decrease since 7:00 on May 12)	O.P.+ 2,835 mm (29 mm decrease since 7:00 on May 12)	O.P.+ 2,829 mm (2 mm decrease since 7:00 on May 12)
	Water level of Reactor Building	O.P.+ 4,659 mm (28 mm increase since 7:00 on May 12)	O.P.+ 3,061 mm (8 mm decrease since 7:00 on May 12)	O.P.+ 2,878 mm (34 mm decrease since 7:00 on May 12)	O.P.+ 2,818 mm (1 mm increase since 7:00 on May 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,529 mm (Increase from initial level:5,746 mm, 10 mm increase since 7:00 on May 12) O.P.+ 2,198 mm (Increase from initial level:2,924 mm, 426 mm increase since 7:00 on May 12) O.P.+ 4,329 mm (Water level from floor:533 mm, 1 mm increase since 7:00 on May 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 11:47 on May 12 to 14:53 on May 12)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:32 on May 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:38 on May 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:20 on May 7 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.