

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 14)**

Water Level of the accumulated water (at 7:00 on May 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 2,009 mm (3 mm increase since 7:00 on May 13)	O.P.+ 1,760 mm (1 mm decrease since 7:00 on May 13)	—
	Water level of Turbine Building	O.P.+ 2,359 mm (13 mm increase since 7:00 on May 13)	O.P.+ 2,931 mm (10 mm decrease since 7:00 on May 13)	O.P.+ 2,809 mm (26 mm decrease since 7:00 on May 13)	O.P.+ 2,818 mm (11 mm decrease since 7:00 on May 13)
	Water level of Reactor Building	O.P.+ 4,572 mm (87 mm decrease since 7:00 on May 13)	O.P.+ 3,043 mm (18 mm decrease since 7:00 on May 13)	O.P.+ 2,844 mm (34 mm decrease since 7:00 on May 13)	O.P.+ 2,810 mm (8 mm decrease since 7:00 on May 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,536 mm (Increase from initial level:5,753 mm, 7 mm increase since 7:00 on May 13) O.P.+ 2,625 mm (Increase from initial level:3,351 mm, 427 mm increase since 7:00 on May 13) O.P.+ 4,332 mm (Water level from floor:536 mm, 3 mm increase since 7:00 on May 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:32 on May 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 14:38 on May 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on May 14   Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.