

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 15)**

Water Level of the accumulated water (at 7:00 on May 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 622 mm (1,387 mm decrease since 7:00 on May 14)	O.P.+ 1,775 mm (15 mm increase since 7:00 on May 14)	—
	Water level of Turbine Building	O.P.+ 2,368 mm (9 mm increase since 7:00 on May 14)	O.P.+ 2,921 mm (10 mm decrease since 7:00 on May 14)	O.P.+ 2,910 mm (101 mm increase since 7:00 on May 14)	O.P.+ 2,818 mm (No change since 7:00 on May 14)
	Water level of Reactor Building	O.P.+ 4,510 mm (62 mm decrease since 7:00 on May 14)	O.P.+ 3,049 mm (6 mm increase since 7:00 on May 14)	O.P.+ 2,953 mm (109 mm increase since 7:00 on May 14)	O.P.+ 2,808 mm (2 mm decrease since 7:00 on May 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,542 mm (Increase from initial level:5,759 mm, 6 mm increase since 7:00 on May 14) O.P.+ 2,429 mm (Increase from initial level:3,155 mm, 196 mm decrease since 7:00 on May 14) O.P.+ 4,334 mm (Water level from floor:538 mm, 2 mm increase since 7:00 on May 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 14:01 on May 14)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 14:38 on May 11 to 9:55 on May 14)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on May 14 to 15:00 on May 14)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:56 on May 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.