

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 16)**

Water Level of the accumulated water (at 7:00 on May 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 707 mm (85 mm increase since 7:00 on May 15)	O.P.+ 2,715 mm (940 mm increase since 7:00 on May 15)	—
	Water level of Turbine Building	O.P.+ 2,375 mm (7 mm increase since 7:00 on May 15)	O.P.+ 2,990 mm (69 mm increase since 7:00 on May 15)	O.P.+ 2,945 mm (35 mm increase since 7:00 on May 15)	O.P.+ 2,838 mm (20 mm increase since 7:00 on May 15)
	Water level of Reactor Building	O.P.+ 4,426 mm (84 mm decrease since 7:00 on May 15)	O.P.+ 3,081 mm (32 mm increase since 7:00 on May 15)	O.P.+ 2,998 mm (45 mm increase since 7:00 on May 15)	O.P.+ 2,823 mm (15 mm increase since 7:00 on May 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,549 mm (Increase from initial level:5,766 mm, 7 mm increase since 7:00 on May 15) O.P.+ 1,767 mm (Increase from initial level:2,493 mm, 662 mm decrease since 7:00 on May 15) O.P.+ 4,336 mm (Water level from floor:540 mm, 2 mm increase since 7:00 on May 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
			Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 14:01 on May 14 to 10:03 on May 15)		
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on May 15 to 15:00 on May 15)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:56 on May 14   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.