

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 17)**

Water Level of the accumulated water (at 7:00 on May 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 764 mm (57 mm increase since 7:00 on May 16)	O.P.+ 2,725 mm (10 mm increase since 7:00 on May 16)	—
	Water level of Turbine Building	O.P.+ 2,382 mm (7 mm increase since 7:00 on May 16)	O.P.+ 2,989 mm (1 mm decrease since 7:00 on May 16)	O.P.+ 2,891 mm (54 mm decrease since 7:00 on May 16)	O.P.+ 2,851 mm (13 mm increase since 7:00 on May 16)
	Water level of Reactor Building	O.P.+ 4,372 mm (54 mm decrease since 7:00 on May 16)	O.P.+ 3,107 mm (26 mm increase since 7:00 on May 16)	O.P.+ 2,943 mm (55 mm decrease since 7:00 on May 16)	O.P.+ 2,837 mm (14 mm increase since 7:00 on May 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,552 mm (Increase from initial level:5,769 mm, 3 mm increase since 7:00 on May 16) O.P.+ 1,897 mm (Increase from initial level:2,623 mm, 130 mm increase since 7:00 on May 16) O.P.+ 4,337 mm (Water level from floor:541 mm, 1 mm increase since 7:00 on May 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
			Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:41 on May 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:10 on May 16)	
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:56 on May 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.