

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 18)**

Water Level of the accumulated water (at 7:00 on May 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 799 mm (35 mm increase since 7:00 on May 17)	O.P.+ 2,715 mm (10 mm decrease since 7:00 on May 17)	—
	Water level of Turbine Building	O.P.+ 2,388 mm (6 mm increase since 7:00 on May 17)	O.P.+ 2,971 mm (18 mm decrease since 7:00 on May 17)	O.P.+ 2,850 mm (41 mm decrease since 7:00 on May 17)	O.P.+ 2,845 mm (6 mm decrease since 7:00 on May 17)
	Water level of Reactor Building	O.P.+ 4,334 mm (38 mm decrease since 7:00 on May 17)	O.P.+ 3,089 mm (18 mm decrease since 7:00 on May 17)	O.P.+ 2,890 mm (53 mm decrease since 7:00 on May 17)	O.P.+ 2,834 mm (3 mm decrease since 7:00 on May 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,555 mm (Increase from initial level:5,772 mm, 3 mm increase since 7:00 on May 17) O.P.+ 2,215 mm (Increase from initial level:2,941 mm, 318 mm increase since 7:00 on May 17) O.P.+ 4,337 mm (Water level from floor:541 mm, No change since 7:00 on May 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
			Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:10 on May 16)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:41 on May 16)	
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:56 on May 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.