

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 19)**

Water Level of the accumulated water (at 7:00 on May 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 835 mm (36 mm increase since 7:00 on May 18)	O.P.+ -4 mm (2,719 mm decrease since 7:00 on May 18)	—
	Water level of Turbine Building	O.P.+ 2,395 mm (7 mm increase since 7:00 on May 18)	O.P.+ 2,933 mm (38 mm decrease since 7:00 on May 18)	O.P.+ 2,966 mm (116 mm increase since 7:00 on May 18)	O.P.+ 2,852 mm (7 mm increase since 7:00 on May 18)
	Water level of Reactor Building	O.P.+ 4,363 mm (29 mm increase since 7:00 on May 18)	O.P.+ 3,077 mm (12 mm decrease since 7:00 on May 18)	O.P.+ 3,023 mm (133 mm increase since 7:00 on May 18)	O.P.+ 2,837 mm (3 mm increase since 7:00 on May 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,561 mm (Increase from initial level:5,778 mm, 6 mm increase since 7:00 on May 18) O.P.+ 1,730 mm (Increase from initial level:2,456 mm, 485 mm decrease since 7:00 on May 18) O.P.+ 4,338 mm (Water level from floor:542 mm, 1 mm increase since 7:00 on May 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 10:51 on May 18)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (From 10:41 on May 16 to 9:41 on May 18)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:56 on May 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.