

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 20)**

Water Level of the accumulated water (at 7:00 on May 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 878 mm (43 mm increase since 7:00 on May 19)	O.P.+ -9 mm (5 mm decrease since 7:00 on May 19)	—
	Water level of Turbine Building	O.P.+ 2,425 mm (30 mm increase since 7:00 on May 19)	O.P.+ 2,925 mm (8 mm decrease since 7:00 on May 19)	O.P.+ 2,959 mm (7 mm decrease since 7:00 on May 19)	O.P.+ 2,872 mm (20 mm increase since 7:00 on May 19)
	Water level of Reactor Building	O.P.+ 4,421 mm (58 mm increase since 7:00 on May 19)	O.P.+ 3,060 mm (17 mm decrease since 7:00 on May 19)	O.P.+ 3,022 mm (1 mm decrease since 7:00 on May 19)	O.P.+ 2,850 mm (13 mm increase since 7:00 on May 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,572 mm (Increase from initial level:5,789 mm, 11 mm increase since 7:00 on May 19) O.P.+ 1,742 mm (Increase from initial level:2,468 mm, 12 mm increase since 7:00 on May 19) O.P.+ 4,342 mm (Water level from floor:546 mm, 4 mm increase since 7:00 on May 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:53 on May 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:40 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:56 on May 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.