

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 21)**

Water Level of the accumulated water (at 7:00 on May 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 905 mm (27 mm increase since 7:00 on May 20)	O.P.+ -20 mm (11 mm decrease since 7:00 on May 20)	—
	Water level of Turbine Building	O.P.+ 2,438 mm (13 mm increase since 7:00 on May 20)	O.P.+ 2,919 mm (6 mm decrease since 7:00 on May 20)	O.P.+ 2,903 mm (56 mm decrease since 7:00 on May 20)	O.P.+ 2,878 mm (6 mm increase since 7:00 on May 20)
	Water level of Reactor Building	O.P.+ 4,416 mm (5 mm decrease since 7:00 on May 20)	O.P.+ 3,039 mm (21 mm decrease since 7:00 on May 20)	O.P.+ 2,958 mm (64 mm decrease since 7:00 on May 20)	O.P.+ 2,863 mm (13 mm increase since 7:00 on May 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,575 mm (Increase from initial level:5,792 mm, 3 mm increase since 7:00 on May 20) O.P.+ 2,142 mm (Increase from initial level:2,868 mm, 400 mm increase since 7:00 on May 20) O.P.+ 4,343 mm (Water level from floor:547 mm, 1 mm increase since 7:00 on May 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:53 on May 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:40 on May 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on May 20 to 15:00 on May 20)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 19:56 on May 14 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.