

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 22)**

Water Level of the accumulated water (at 7:00 on May 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 929 mm (24 mm increase since 7:00 on May 21)	O.P.+ -31 mm (11 mm decrease since 7:00 on May 21)	—
	Water level of Turbine Building	O.P.+ 2,450 mm (12 mm increase since 7:00 on May 21)	O.P.+ 2,906 mm (13 mm decrease since 7:00 on May 21)	O.P.+ 2,865 mm (38 mm decrease since 7:00 on May 21)	O.P.+ 2,870 mm (8 mm decrease since 7:00 on May 21)
	Water level of Reactor Building	O.P.+ 4,387 mm (29 mm decrease since 7:00 on May 21)	O.P.+ 3,010 mm (29 mm decrease since 7:00 on May 21)	O.P.+ 2,911 mm (47 mm decrease since 7:00 on May 21)	O.P.+ 2,858 mm (5 mm decrease since 7:00 on May 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,578 mm (Increase from initial level:5,795 mm, 3 mm increase since 7:00 on May 21) O.P.+ 2,635 mm (Increase from initial level:3,361 mm, 493 mm increase since 7:00 on May 21) O.P.+ 4,345 mm (Water level from floor:549 mm, 2 mm increase since 7:00 on May 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:53 on May 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:40 on May 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:38 on May 21   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.