

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 23)**

Water Level of the accumulated water (at 7:00 on May 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 950 mm (21 mm increase since 7:00 on May 22)	O.P.+ -35 mm (4 mm decrease since 7:00 on May 22)	—
	Water level of Turbine Building	O.P.+ 2,462 mm (12 mm increase since 7:00 on May 22)	O.P.+ 2,890 mm (16 mm decrease since 7:00 on May 22)	O.P.+ 2,834 mm (31 mm decrease since 7:00 on May 22)	O.P.+ 2,857 mm (13 mm decrease since 7:00 on May 22)
	Water level of Reactor Building	O.P.+ 4,357 mm (30 mm decrease since 7:00 on May 22)	O.P.+ 3,007 mm (3 mm decrease since 7:00 on May 22)	O.P.+ 2,872 mm (39 mm decrease since 7:00 on May 22)	O.P.+ 2,849 mm (9 mm decrease since 7:00 on May 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,584 mm (Increase from initial level:5,801 mm, 6 mm increase since 7:00 on May 22) O.P.+ 3,038 mm (Increase from initial level:3,764 mm, 403 mm increase since 7:00 on May 22) O.P.+ 4,346 mm (Water level from floor:550 mm, 1 mm increase since 7:00 on May 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:53 on May 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 15:40 on May 19)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:38 on May 21 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.