

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 24)**

|  |  |   |  |  |   |
|--|--|---|--|--|---|
| Water Level of the accumulated water (at 7:00 on May 24) |  | Unit 1  | Unit 2   | Unit 3   | Unit 4  |
|  | Water level of Vertical Shaft  | Unmeasurable due to drawdown of water level<br>(Less than O.P.+ 850 mm)   | O.P.+ 972 mm<br>(22 mm increase since 7:00 on May 23)  | O.P.+ -32 mm<br>(3 mm increase since 7:00 on May 23)   | —   |
|  | Water level of Turbine Building  | O.P.+ 2,475 mm<br>(13 mm increase since 7:00 on May 23)   | O.P.+ 2,873 mm<br>(17 mm decrease since 7:00 on May 23)  | O.P.+ 2,805 mm<br>(29 mm decrease since 7:00 on May 23)  | O.P.+ 2,841 mm<br>(16 mm decrease since 7:00 on May 23) |
|  | Water level of Reactor Building  | O.P.+ 4,325 mm<br>(32 mm decrease since 7:00 on May 23)   | O.P.+ 2,994 mm<br>(13 mm decrease since 7:00 on May 23)  | O.P.+ 2,840 mm<br>(32 mm decrease since 7:00 on May 23)  | O.P.+ 2,836 mm<br>(13 mm decrease since 7:00 on May 23) |
|  | Water level of each building in the Centralized Radiation Waste Treatment Facility | Process Main Building<br>High Temperature Incinerator Building<br>On-site Bunker Building   | O.P.+ 4,585 mm (Increase from initial level:5,802 mm, 1 mm increase since 7:00 on May 23)<br>O.P.+ 3,557 mm (Increase from initial level:4,283 mm, 519 mm increase since 7:00 on May 23)<br>O.P.+ 4,347 mm (Water level from floor:551 mm, 1 mm increase since 7:00 on May 23) |  |   |
| Situation of transfer of the accumulated water           |  | Unit 1  | Unit 2   | Unit 3   | Unit 4  |
|  |  | —   | Basement of Unit 2 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 15:53 on May 19)   | Basement of Unit 3 Turbine Building<br>→Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building)<br>Currently being transferred<br>(Since 15:40 on May 19) | —   |
|  |  | Unit 5 and 6  |  |  |   |
|  |  | —   |  |  |   |
| Operation condition of water treatment facility          |  | Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended<br>2nd Cesium Adsorption Apparatus (Sarry): Since 13:38 on May 21   In operation<br>Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance<br>Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance |  |  |   |
| Notes  |  |   |  |  |   |

※ For quick publication of the data of water level, values are provided as reference values.