

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 25)**

Water Level of the accumulated water (at 7:00 on May 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 992 mm (20 mm increase since 7:00 on May 24)	O.P.+ -30 mm (2 mm increase since 7:00 on May 24)	—
	Water level of Turbine Building	O.P.+ 2,486 mm (11 mm increase since 7:00 on May 24)	O.P.+ 2,834 mm (39 mm decrease since 7:00 on May 24)	O.P.+ 2,920 mm (115 mm increase since 7:00 on May 24)	O.P.+ 2,838 mm (3 mm decrease since 7:00 on May 24)
	Water level of Reactor Building	O.P.+ 4,291 mm (34 mm decrease since 7:00 on May 24)	O.P.+ 2,969 mm (25 mm decrease since 7:00 on May 24)	O.P.+ 2,968 mm (128 mm increase since 7:00 on May 24)	O.P.+ 2,830 mm (6 mm decrease since 7:00 on May 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,589 mm (Increase from initial level:5,806 mm, 4 mm increase since 7:00 on May 24) O.P.+ 2,973 mm (Increase from initial level:3,699 mm, 584 mm decrease since 7:00 on May 24) O.P.+ 4,350 mm (Water level from floor:554 mm, 3 mm increase since 7:00 on May 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:08 on May 24)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 15:40 on May 19 to 10:01 on May 24)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:38 on May 21   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.