

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 26)**

Water Level of the accumulated water (at 7:00 on May 26)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,010 mm (18 mm increase since 7:00 on May 25)	O.P.+ -24 mm (6 mm increase since 7:00 on May 25)	—
	Water level of Turbine Building	O.P.+ 2,483 mm (3 mm decrease since 7:00 on May 25)	O.P.+ 2,900 mm (66 mm increase since 7:00 on May 25)	O.P.+ 2,944 mm (24 mm increase since 7:00 on May 25)	O.P.+ 2,855 mm (17 mm increase since 7:00 on May 25)
	Water level of Reactor Building	O.P.+ 4,250 mm (41 mm decrease since 7:00 on May 25)	O.P.+ 2,988 mm (19 mm increase since 7:00 on May 25)	O.P.+ 3,000 mm (32 mm increase since 7:00 on May 25)	O.P.+ 2,842 mm (12 mm increase since 7:00 on May 25)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,592 mm (Increase from initial level:5,809 mm, 3 mm increase since 7:00 on May 25) O.P.+ 2,407 mm (Increase from initial level:3,133 mm, 566 mm decrease since 7:00 on May 25) O.P.+ 4,349 mm (Water level from floor:553 mm, 1 mm decrease since 7:00 on May 25)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Currently being transferred (Since 6:06 on May 26)	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Transfer Completed (From 11:08 on May 24 to 9:40 on May 25)	—	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:23 on May 26 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.