

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 27)**

Water Level of the accumulated water (at 7:00 on May 27)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,025 mm (15 mm increase since 7:00 on May 26)	O.P.+ -11 mm (13 mm increase since 7:00 on May 26)	—
	Water level of Turbine Building	O.P.+ 2,381 mm (102 mm decrease since 7:00 on May 26)	O.P.+ 2,930 mm (30 mm increase since 7:00 on May 26)	O.P.+ 2,900 mm (44 mm decrease since 7:00 on May 26)	O.P.+ 2,865 mm (10 mm increase since 7:00 on May 26)
	Water level of Reactor Building	O.P.+ 4,229 mm (21 mm decrease since 7:00 on May 26)	O.P.+ 3,042 mm (54 mm increase since 7:00 on May 26)	O.P.+ 2,953 mm (47 mm decrease since 7:00 on May 26)	O.P.+ 2,853 mm (11 mm increase since 7:00 on May 26)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,594 mm (Increase from initial level:5,811 mm, 2 mm increase since 7:00 on May 26) O.P.+ 2,921 mm (Increase from initial level:3,647 mm, 514 mm increase since 7:00 on May 26) O.P.+ 4,351 mm (Water level from floor:555 mm, 2 mm increase since 7:00 on May 26)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 6:06 on May 26 to 9:50 on May 26)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:11 on May 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:20 on May 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 20:11 on May 26   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.