

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 28)**

Water Level of the accumulated water (at 7:00 on May 28)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,037 mm (12 mm increase since 7:00 on May 27)	O.P.+ -2 mm (9 mm increase since 7:00 on May 27)	—
	Water level of Turbine Building	O.P.+ 2,459 mm (78 mm increase since 7:00 on May 27)	O.P.+ 2,908 mm (22 mm decrease since 7:00 on May 27)	O.P.+ 2,877 mm (23 mm decrease since 7:00 on May 27)	O.P.+ 2,863 mm (2 mm decrease since 7:00 on May 27)
	Water level of Reactor Building	O.P.+ 4,201 mm (28 mm decrease since 7:00 on May 27)	O.P.+ 3,025 mm (17 mm decrease since 7:00 on May 27)	O.P.+ 2,928 mm (25 mm decrease since 7:00 on May 27)	O.P.+ 2,851 mm (2 mm decrease since 7:00 on May 27)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,598 mm (Increase from initial level:5,815 mm, 4 mm increase since 7:00 on May 27) O.P.+ 3,318 mm (Increase from initial level:4,044 mm, 397 mm increase since 7:00 on May 27) O.P.+ 4,352 mm (Water level from floor:556 mm, 1 mm increase since 7:00 on May 27)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:11 on May 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:20 on May 26)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 20:47 on May 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.