

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 29)**

Water Level of the accumulated water (at 7:00 on May 29)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,049 mm (12 mm increase since 7:00 on May 28)	O.P.+ 2,523 mm (2,525 mm increase since 7:00 on May 28)	—
	Water level of Turbine Building	O.P.+ 2,529 mm (70 mm increase since 7:00 on May 28)	O.P.+ 2,885 mm (23 mm decrease since 7:00 on May 28)	O.P.+ 2,852 mm (25 mm decrease since 7:00 on May 28)	O.P.+ 2,856 mm (7 mm decrease since 7:00 on May 28)
	Water level of Reactor Building	O.P.+ 4,173 mm (28 mm decrease since 7:00 on May 28)	O.P.+ 3,007 mm (18 mm decrease since 7:00 on May 28)	O.P.+ 2,896 mm (32 mm decrease since 7:00 on May 28)	O.P.+ 2,846 mm (5 mm decrease since 7:00 on May 28)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,604 mm (Increase from initial level:5,821 mm, 6 mm increase since 7:00 on May 28) O.P.+ 3,728 mm (Increase from initial level:4,454 mm, 410 mm increase since 7:00 on May 28) O.P.+ 4,354 mm (Water level from floor:558 mm, 2 mm increase since 7:00 on May 28)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:11 on May 26)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:20 on May 26)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank		Transfer Completed	(From 10:00 on May 28 to 15:00 on May 28)
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:01 on April 24   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 20:47 on May 26   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.