

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on May 31)**

Water Level of the accumulated water (at 7:00 on May 31)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,069 mm (9 mm increase since 7:00 on May 30)	O.P.+ 2,523 mm (No change since 7:00 on May 30)	—
	Water level of Turbine Building	O.P.+ 2,550 mm (12 mm increase since 7:00 on May 30)	O.P.+ 2,810 mm (50 mm decrease since 7:00 on May 30)	O.P.+ 2,935 mm (34 mm increase since 7:00 on May 30)	O.P.+ 2,865 mm (12 mm increase since 7:00 on May 30)
	Water level of Reactor Building	O.P.+ 4,128 mm (26 mm decrease since 7:00 on May 30)	O.P.+ 2,954 mm (40 mm decrease since 7:00 on May 30)	O.P.+ 2,989 mm (39 mm increase since 7:00 on May 30)	O.P.+ 2,852 mm (9 mm increase since 7:00 on May 30)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,678 mm (Increase from initial level:5,895 mm, 39 mm increase since 7:00 on May 30) O.P.+ 2,312 mm (Increase from initial level:3,038 mm, 688 mm decrease since 7:00 on May 30) O.P.+ 4,356 mm (Water level from floor:560 mm, 1 mm increase since 7:00 on May 30)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 11:22 on May 29)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:14 on May 29)	—
		Unit 5 and 6			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:00 on May 29 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 20:47 on May 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.