

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 1)**

Water Level of the accumulated water (at 7:00 on June 1)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,078 mm (9 mm increase since 7:00 on May 31)	O.P.+ 2,521 mm (2 mm decrease since 7:00 on May 31)	—
	Water level of Turbine Building	O.P.+ 2,559 mm (9 mm increase since 7:00 on May 31)	O.P.+ 2,797 mm (13 mm decrease since 7:00 on May 31)	O.P.+ 2,892 mm (43 mm decrease since 7:00 on May 31)	O.P.+ 2,871 mm (6 mm increase since 7:00 on May 31)
	Water level of Reactor Building	O.P.+ 4,067 mm (61 mm decrease since 7:00 on May 31)	O.P.+ 2,931 mm (23 mm decrease since 7:00 on May 31)	O.P.+ 2,946 mm (43 mm decrease since 7:00 on May 31)	O.P.+ 2,859 mm (7 mm increase since 7:00 on May 31)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,535 mm (Increase from initial level:5,752 mm, 143 mm decrease since 7:00 on May 31) O.P.+ 2,429 mm (Increase from initial level:3,155 mm, 117 mm increase since 7:00 on May 31) O.P.+ 4,358 mm (Water level from floor:562 mm, 2 mm increase since 7:00 on May 31)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:55 on May 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:11 on May 31)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:00 on May 29 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 20:47 on May 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.