

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 2)**

Water Level of the accumulated water (at 7:00 on June 2)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,087 mm (9 mm increase since 7:00 on June 1)	O.P.+ 2,522 mm (1 mm increase since 7:00 on June 1)	—
	Water level of Turbine Building	O.P.+ 2,567 mm (8 mm increase since 7:00 on June 1)	O.P.+ 2,781 mm (16 mm decrease since 7:00 on June 1)	O.P.+ 2,856 mm (36 mm decrease since 7:00 on June 1)	O.P.+ 2,866 mm (5 mm decrease since 7:00 on June 1)
	Water level of Reactor Building	O.P.+ 4,010 mm (57 mm decrease since 7:00 on June 1)	O.P.+ 2,917 mm (14 mm decrease since 7:00 on June 1)	O.P.+ 2,902 mm (44 mm decrease since 7:00 on June 1)	O.P.+ 2,856 mm (3 mm decrease since 7:00 on June 1)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,350 mm (Increase from initial level:5,567 mm, 185 mm decrease since 7:00 on June 1) O.P.+ 2,731 mm (Increase from initial level:3,457 mm, 302 mm increase since 7:00 on June 1) O.P.+ 4,359 mm (Water level from floor:563 mm, 1 mm increase since 7:00 on June 1)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:55 on May 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:11 on May 31)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 1 to 15:00 on June 1)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 12:00 on May 29 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 20:47 on May 26 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.