

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 3)**

Water Level of the accumulated water (at 7:00 on June 3)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,092 mm (5 mm increase since 7:00 on June 2)	O.P.+ 1,427 mm (1,095 mm decrease since 7:00 on June 2)	—
	Water level of Turbine Building	O.P.+ 2,576 mm (9 mm increase since 7:00 on June 2)	O.P.+ 2,789 mm (8 mm increase since 7:00 on June 2)	O.P.+ 2,846 mm (10 mm decrease since 7:00 on June 2)	O.P.+ 2,858 mm (8 mm decrease since 7:00 on June 2)
	Water level of Reactor Building	O.P.+ 3,969 mm (41 mm decrease since 7:00 on June 2)	O.P.+ 2,925 mm (8 mm increase since 7:00 on June 2)	O.P.+ 2,889 mm (13 mm decrease since 7:00 on June 2)	O.P.+ 2,849 mm (7 mm decrease since 7:00 on June 2)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,340 mm (Increase from initial level:5,557 mm, 10 mm decrease since 7:00 on June 2) O.P.+ 3,091 mm (Increase from initial level:3,817 mm, 360 mm increase since 7:00 on June 2) O.P.+ 4,361 mm (Water level from floor:565 mm, 2 mm increase since 7:00 on June 2)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:55 on May 31)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:11 on May 31)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:56 on June 2   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 20:47 on May 26   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.