

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 4)**

Water Level of the accumulated water (at 7:00 on June 4)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 327 mm (765 mm decrease since 7:00 on June 3)	O.P.+ 1,432 mm (5 mm increase since 7:00 on June 3)	—
	Water level of Turbine Building	O.P.+ 2,653 mm (77 mm increase since 7:00 on June 3)	O.P.+ 2,761 mm (28 mm decrease since 7:00 on June 3)	O.P.+ 2,887 mm (41 mm increase since 7:00 on June 3)	O.P.+ 2,850 mm (8 mm decrease since 7:00 on June 3)
	Water level of Reactor Building	O.P.+ 3,938 mm (31 mm decrease since 7:00 on June 3)	O.P.+ 2,914 mm (11 mm decrease since 7:00 on June 3)	O.P.+ 2,937 mm (48 mm increase since 7:00 on June 3)	O.P.+ 2,842 mm (7 mm decrease since 7:00 on June 3)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,546 mm (Increase from initial level:5,763 mm, 206 mm increase since 7:00 on June 3) O.P.+ 2,691 mm (Increase from initial level:3,417 mm, 400 mm decrease since 7:00 on June 3) O.P.+ 4,362 mm (Water level from floor:566 mm, 1 mm increase since 7:00 on June 3)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 12:03 on June 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:25 on June 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 3 to 15:00 on June 3)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:56 on June 2   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:49 on June 3   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.