

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 5)**

Water Level of the accumulated water (at 7:00 on June 5)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 431 mm (104 mm increase since 7:00 on June 4)	O.P.+ 1,417 mm (15 mm decrease since 7:00 on June 4)	—
	Water level of Turbine Building	O.P.+ 2,659 mm (6 mm increase since 7:00 on June 4)	O.P.+ 2,712 mm (49 mm decrease since 7:00 on June 4)	O.P.+ 2,930 mm (43 mm increase since 7:00 on June 4)	O.P.+ 2,860 mm (10 mm increase since 7:00 on June 4)
	Water level of Reactor Building	O.P.+ 3,900 mm (38 mm decrease since 7:00 on June 4)	O.P.+ 2,864 mm (50 mm decrease since 7:00 on June 4)	O.P.+ 2,985 mm (48 mm increase since 7:00 on June 4)	O.P.+ 2,847 mm (5 mm increase since 7:00 on June 4)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,619 mm (Increase from initial level:5,836 mm, 73 mm increase since 7:00 on June 4) O.P.+ 2,057 mm (Increase from initial level:2,783 mm, 634 mm decrease since 7:00 on June 4) O.P.+ 4,362 mm (Water level from floor:566 mm, No change since 7:00 on June 4)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Basement of Unit 3 Turbine Building Currently being transferred (Since 12:03 on June 3)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:25 on June 3)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 4 to 15:00 on June 4)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:17 on June 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:49 on June 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.