

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 6)**

Water Level of the accumulated water (at 7:00 on June 6)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 500 mm (69 mm increase since 7:00 on June 5)	O.P.+ 1,418 mm (1 mm increase since 7:00 on June 5)	—
	Water level of Turbine Building	O.P.+ 2,669 mm (10 mm increase since 7:00 on June 5)	O.P.+ 2,779 mm (67 mm increase since 7:00 on June 5)	O.P.+ 2,889 mm (41 mm decrease since 7:00 on June 5)	O.P.+ 2,866 mm (6 mm increase since 7:00 on June 5)
	Water level of Reactor Building	O.P.+ 3,874 mm (26 mm decrease since 7:00 on June 5)	O.P.+ 2,878 mm (14 mm increase since 7:00 on June 5)	O.P.+ 2,943 mm (42 mm decrease since 7:00 on June 5)	O.P.+ 2,855 mm (8 mm increase since 7:00 on June 5)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,465 mm (Increase from initial level:5,682 mm, 154 mm decrease since 7:00 on June 5) O.P.+ 1,836 mm (Increase from initial level:2,562 mm, 221 mm decrease since 7:00 on June 5) O.P.+ 4,363 mm (Water level from floor:567 mm, 1 mm increase since 7:00 on June 5)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:19 on June 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:30 on June 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:17 on June 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:49 on June 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.