

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 8)**

Water Level of the accumulated water (at 7:00 on June 8)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 569 mm (27 mm increase since 7:00 on June 7)	O.P.+ 1,424 mm (5 mm increase since 7:00 on June 7)	—
	Water level of Turbine Building	O.P.+ 2,682 mm (6 mm increase since 7:00 on June 7)	O.P.+ 2,762 mm (20 mm decrease since 7:00 on June 7)	O.P.+ 2,817 mm (32 mm decrease since 7:00 on June 7)	O.P.+ 2,849 mm (10 mm decrease since 7:00 on June 7)
	Water level of Reactor Building	O.P.+ 3,847 mm (16 mm decrease since 7:00 on June 7)	O.P.+ 2,893 mm (11 mm decrease since 7:00 on June 7)	O.P.+ 2,860 mm (35 mm decrease since 7:00 on June 7)	O.P.+ 2,842 mm (8 mm decrease since 7:00 on June 7)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,128 mm (Increase from initial level:5,345 mm, 156 mm decrease since 7:00 on June 7) O.P.+ 2,395 mm (Increase from initial level:3,121 mm, 352 mm increase since 7:00 on June 7) O.P.+ 4,366 mm (Water level from floor:570 mm, 1 mm increase since 7:00 on June 7)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:19 on June 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:30 on June 5)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:17 on June 4 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 13:49 on June 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.