

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 9)**

Water Level of the accumulated water (at 7:00 on June 9)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 591 mm (22 mm increase since 7:00 on June 8)	O.P.+ 1,433 mm (9 mm increase since 7:00 on June 8)	—
	Water level of Turbine Building	O.P.+ 2,689 mm (7 mm increase since 7:00 on June 8)	O.P.+ 2,754 mm (8 mm decrease since 7:00 on June 8)	O.P.+ 2,788 mm (29 mm decrease since 7:00 on June 8)	O.P.+ 2,833 mm (16 mm decrease since 7:00 on June 8)
	Water level of Reactor Building	O.P.+ 3,834 mm (13 mm decrease since 7:00 on June 8)	O.P.+ 2,890 mm (3 mm decrease since 7:00 on June 8)	O.P.+ 2,825 mm (35 mm decrease since 7:00 on June 8)	O.P.+ 2,833 mm (9 mm decrease since 7:00 on June 8)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,121 mm (Increase from initial level:5,338 mm, 7 mm decrease since 7:00 on June 8) O.P.+ 2,780 mm (Increase from initial level:3,506 mm, 385 mm increase since 7:00 on June 8) O.P.+ 4,367 mm (Water level from floor:571 mm, 1 mm increase since 7:00 on June 8)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:19 on June 5)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 11:30 on June 5)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 8 to 15:00 on June 8)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:03 on June 8 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:49 on June 3 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.