

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 10)**

Water Level of the accumulated water (at 7:00 on June 10)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 622 mm (31 mm increase since 7:00 on June 9)	O.P.+ 1,435 mm (2 mm increase since 7:00 on June 9)	—
	Water level of Turbine Building	O.P.+ 2,699 mm (10 mm increase since 7:00 on June 9)	O.P.+ 2,752 mm (2 mm decrease since 7:00 on June 9)	O.P.+ 2,767 mm (21 mm decrease since 7:00 on June 9)	O.P.+ 2,819 mm (14 mm decrease since 7:00 on June 9)
	Water level of Reactor Building	O.P.+ 3,903 mm (69 mm increase since 7:00 on June 9)	O.P.+ 2,904 mm (14 mm increase since 7:00 on June 9)	O.P.+ 2,800 mm (25 mm decrease since 7:00 on June 9)	O.P.+ 2,819 mm (14 mm decrease since 7:00 on June 9)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,462 mm (Increase from initial level:5,679 mm, 341 mm increase since 7:00 on June 9) O.P.+ 2,382 mm (Increase from initial level:3,108 mm, 398 mm decrease since 7:00 on June 9) O.P.+ 4,369 mm (Water level from floor:573 mm, 2 mm increase since 7:00 on June 9)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:37 on June 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:40 on June 9)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:03 on June 9 to 15:00 on June 9)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:03 on June 8   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 13:49 on June 3   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.