

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 11)**

Water Level of the accumulated water (at 7:00 on June 11)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 637 mm (15 mm increase since 7:00 on June 10)	O.P.+ 2,249 mm (814 mm increase since 7:00 on June 10)	—
	Water level of Turbine Building	O.P.+ 2,710 mm (11 mm increase since 7:00 on June 10)	O.P.+ 2,780 mm (28 mm increase since 7:00 on June 10)	O.P.+ 2,740 mm (27 mm decrease since 7:00 on June 10)	O.P.+ 2,802 mm (17 mm decrease since 7:00 on June 10)
	Water level of Reactor Building	O.P.+ 3,915 mm (12 mm increase since 7:00 on June 10)	O.P.+ 2,913 mm (9 mm increase since 7:00 on June 10)	O.P.+ 2,769 mm (31 mm decrease since 7:00 on June 10)	O.P.+ 2,812 mm (7 mm decrease since 7:00 on June 10)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,852 mm (Increase from initial level:6,069 mm, 390 mm increase since 7:00 on June 10) O.P.+ 1,836 mm (Increase from initial level:2,562 mm, 546 mm decrease since 7:00 on June 10) O.P.+ 4,371 mm (Water level from floor:575 mm, 2 mm increase since 7:00 on June 10)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:37 on June 9)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:40 on June 9)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 10 to 15:00 on June 10)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:03 on June 8 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:35 on June 11 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.