

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 12)**

Water Level of the accumulated water (at 7:00 on June 12)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 641 mm (4 mm increase since 7:00 on June 11)	O.P.+ 1,429 mm (820 mm decrease since 7:00 on June 11)	—
	Water level of Turbine Building	O.P.+ 2,720 mm (10 mm increase since 7:00 on June 11)	O.P.+ 2,775 mm (5 mm decrease since 7:00 on June 11)	O.P.+ 2,755 mm (15 mm increase since 7:00 on June 11)	O.P.+ 2,789 mm (13 mm decrease since 7:00 on June 11)
	Water level of Reactor Building	O.P.+ 3,920 mm (5 mm increase since 7:00 on June 11)	O.P.+ 2,916 mm (3 mm increase since 7:00 on June 11)	O.P.+ 2,784 mm (15 mm increase since 7:00 on June 11)	O.P.+ 2,800 mm (12 mm decrease since 7:00 on June 11)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,901 mm (Increase from initial level:6,118 mm, 49 mm increase since 7:00 on June 11) O.P.+ 2,267 mm (Increase from initial level:2,993 mm, 431 mm increase since 7:00 on June 11) O.P.+ 4,371 mm (Water level from floor:575 mm, No change since 7:00 on June 11)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:19 on June 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:03 on June 8   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 11   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.