

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 13)**

Water Level of the accumulated water (at 7:00 on June 13)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 644 mm (3 mm increase since 7:00 on June 12)	O.P.+ 1,447 mm (18 mm increase since 7:00 on June 12)	—
	Water level of Turbine Building	O.P.+ 2,732 mm (12 mm increase since 7:00 on June 12)	O.P.+ 2,766 mm (9 mm decrease since 7:00 on June 12)	O.P.+ 2,728 mm (27 mm decrease since 7:00 on June 12)	O.P.+ 2,776 mm (13 mm decrease since 7:00 on June 12)
	Water level of Reactor Building	O.P.+ 3,920 mm (No change since 7:00 on June 12)	O.P.+ 2,909 mm (7 mm decrease since 7:00 on June 12)	O.P.+ 2,753 mm (31 mm decrease since 7:00 on June 12)	O.P.+ 2,785 mm (15 mm decrease since 7:00 on June 12)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,782 mm (Increase from initial level:5,999 mm, 119 mm decrease since 7:00 on June 12) O.P.+ 2,547 mm (Increase from initial level:3,273 mm, 280 mm increase since 7:00 on June 12) O.P.+ 4,373 mm (Water level from floor:577 mm, 2 mm increase since 7:00 on June 12)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:19 on June 11)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 12 to 15:00 on June 12)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:51 on June 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.