

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 14)**

Water Level of the accumulated water (at 7:00 on June 14)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 646 mm (2 mm increase since 7:00 on June 13)	O.P.+ 2,802 mm (1,355 mm increase since 7:00 on June 13)	—
	Water level of Turbine Building	O.P.+ 2,545 mm (187 mm decrease since 7:00 on June 13)	O.P.+ 2,758 mm (8 mm decrease since 7:00 on June 13)	O.P.+ 2,704 mm (24 mm decrease since 7:00 on June 13)	O.P.+ 2,761 mm (15 mm decrease since 7:00 on June 13)
	Water level of Reactor Building	O.P.+ 3,914 mm (6 mm decrease since 7:00 on June 13)	O.P.+ 2,899 mm (10 mm decrease since 7:00 on June 13)	O.P.+ 2,723 mm (30 mm decrease since 7:00 on June 13)	O.P.+ 2,774 mm (11 mm decrease since 7:00 on June 13)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,631 mm (Increase from initial level:5,848 mm, 151 mm decrease since 7:00 on June 13) O.P.+ 2,856 mm (Increase from initial level:3,582 mm, 309 mm increase since 7:00 on June 13) O.P.+ 4,375 mm (Water level from floor:579 mm, 2 mm increase since 7:00 on June 13)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		Basement of Unit 1 Turbine Building → Transfer Completed (From 10:13 on June 13 to 15:54 on June 13)	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:19 on June 11)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:51 on June 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.