

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 15)**

Water Level of the accumulated water (at 7:00 on June 15)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 658 mm (12 mm increase since 7:00 on June 14)	O.P.+ 2,799 mm (3 mm decrease since 7:00 on June 14)	—
	Water level of Turbine Building	O.P.+ 2,556 mm (11 mm increase since 7:00 on June 14)	O.P.+ 2,753 mm (5 mm decrease since 7:00 on June 14)	O.P.+ 2,684 mm (20 mm decrease since 7:00 on June 14)	O.P.+ 2,746 mm (15 mm decrease since 7:00 on June 14)
	Water level of Reactor Building	O.P.+ 3,905 mm (9 mm decrease since 7:00 on June 14)	O.P.+ 2,893 mm (6 mm decrease since 7:00 on June 14)	O.P.+ 2,699 mm (24 mm decrease since 7:00 on June 14)	O.P.+ 2,762 mm (12 mm decrease since 7:00 on June 14)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,470 mm (Increase from initial level:5,687 mm, 161 mm decrease since 7:00 on June 14) O.P.+ 3,253 mm (Increase from initial level:3,979 mm, 397 mm increase since 7:00 on June 14) O.P.+ 4,376 mm (Water level from floor:580 mm, 1 mm increase since 7:00 on June 14)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:19 on June 11 to 5:40 on June 15)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 10:51 on June 12 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.