

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 16)**

Water Level of the accumulated water (at 7:00 on June 16)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 688 mm (30 mm increase since 7:00 on June 15)	O.P.+ 2,792 mm (7 mm decrease since 7:00 on June 15)	—
	Water level of Turbine Building	O.P.+ 2,568 mm (12 mm increase since 7:00 on June 15)	O.P.+ 2,749 mm (4 mm decrease since 7:00 on June 15)	O.P.+ 2,755 mm (71 mm increase since 7:00 on June 15)	O.P.+ 2,743 mm (3 mm decrease since 7:00 on June 15)
	Water level of Reactor Building	O.P.+ 3,896 mm (9 mm decrease since 7:00 on June 15)	O.P.+ 2,890 mm (3 mm decrease since 7:00 on June 15)	O.P.+ 2,778 mm (79 mm increase since 7:00 on June 15)	O.P.+ 2,759 mm (3 mm decrease since 7:00 on June 15)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,316 mm (Increase from initial level:5,533 mm, 154 mm decrease since 7:00 on June 15) O.P.+ 3,035 mm (Increase from initial level:3,761 mm, 218 mm decrease since 7:00 on June 15) O.P.+ 4,377 mm (Water level from floor:581 mm, 1 mm increase since 7:00 on June 15)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Transfer Completed (From 10:19 on June 11 to 5:40 on June 15)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 15 to 15:00 on June 15)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: From 10:51 on June 12 to 9:00 on June 16 Stop 2nd Cesium Adsorption Apparatus (Sarry): Since 17:33 on June 11 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.