

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 17)**

Water Level of the accumulated water (at 7:00 on June 17)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 685 mm (3 mm decrease since 7:00 on June 16)	O.P.+ 2,625 mm (167 mm decrease since 7:00 on June 16)	—
	Water level of Turbine Building	O.P.+ 2,578 mm (10 mm increase since 7:00 on June 16)	O.P.+ 2,779 mm (30 mm increase since 7:00 on June 16)	O.P.+ 2,818 mm (63 mm increase since 7:00 on June 16)	O.P.+ 2,751 mm (8 mm increase since 7:00 on June 16)
	Water level of Reactor Building	O.P.+ 3,901 mm (5 mm increase since 7:00 on June 16)	O.P.+ 2,914 mm (24 mm increase since 7:00 on June 16)	O.P.+ 2,856 mm (78 mm increase since 7:00 on June 16)	O.P.+ 2,765 mm (6 mm increase since 7:00 on June 16)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,313 mm (Increase from initial level:5,530 mm, 3 mm decrease since 7:00 on June 16) O.P.+ 2,857 mm (Increase from initial level:3,583 mm, 178 mm decrease since 7:00 on June 16) O.P.+ 4,377 mm (Water level from floor:581 mm, No change since 7:00 on June 16)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building Temporary Tank	Transfer Completed	(From 10:00 on June 16 to 15:00 on June 16)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on June 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on June 17 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

For quick publication of the data of water level, values are provided as reference values.