

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 18)**

Water Level of the accumulated water (at 7:00 on June 18)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 680 mm (5 mm decrease since 7:00 on June 17)	O.P.+ 2,417 mm (208 mm decrease since 7:00 on June 17)	—
	Water level of Turbine Building	O.P.+ 2,589 mm (11 mm increase since 7:00 on June 17)	O.P.+ 2,785 mm (6 mm increase since 7:00 on June 17)	O.P.+ 2,856 mm (38 mm increase since 7:00 on June 17)	O.P.+ 2,765 mm (14 mm increase since 7:00 on June 17)
	Water level of Reactor Building	O.P.+ 3,907 mm (6 mm increase since 7:00 on June 17)	O.P.+ 2,919 mm (5 mm increase since 7:00 on June 17)	O.P.+ 2,900 mm (44 mm increase since 7:00 on June 17)	O.P.+ 2,773 mm (8 mm increase since 7:00 on June 17)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,319 mm (Increase from initial level:5,536 mm, 6 mm increase since 7:00 on June 17) O.P.+ 3,428 mm (Increase from initial level:4,154 mm, 571 mm increase since 7:00 on June 17) O.P.+ 4,379 mm (Water level from floor:583 mm, 2 mm increase since 7:00 on June 17)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 17 to 15:00 on June 17)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on June 16 Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 8:34 on June 17 Suspended Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.