

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 19)**

Water Level of the accumulated water (at 7:00 on June 19)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,500 mm (820 mm increase since 7:00 on June 18)	O.P.+ 2,415 mm (2 mm decrease since 7:00 on June 18)	—
	Water level of Turbine Building	O.P.+ 2,600 mm (11 mm increase since 7:00 on June 18)	O.P.+ 2,808 mm (23 mm increase since 7:00 on June 18)	O.P.+ 2,878 mm (22 mm increase since 7:00 on June 18)	O.P.+ 2,778 mm (13 mm increase since 7:00 on June 18)
	Water level of Reactor Building	O.P.+ 3,906 mm (1 mm decrease since 7:00 on June 18)	O.P.+ 2,939 mm (20 mm increase since 7:00 on June 18)	O.P.+ 2,928 mm (28 mm increase since 7:00 on June 18)	O.P.+ 2,788 mm (15 mm increase since 7:00 on June 18)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,325 mm (Increase from initial level:5,542 mm, 6 mm increase since 7:00 on June 18) O.P.+ 3,429 mm (Increase from initial level:4,155 mm, 1 mm increase since 7:00 on June 18) O.P.+ 4,381 mm (Water level from floor:585 mm, 2 mm increase since 7:00 on June 18)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:15 on June 11)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 18 to 15:00 on June 18)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 9:00 on June 16   Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on June 18   In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.