

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 20)**

Water Level of the accumulated water (at 7:00 on June 20)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,473 mm (27 mm decrease since 7:00 on June 19)	O.P.+ 2,412 mm (3 mm decrease since 7:00 on June 19)	—
	Water level of Turbine Building	O.P.+ 2,610 mm (10 mm increase since 7:00 on June 19)	O.P.+ 2,801 mm (7 mm decrease since 7:00 on June 19)	O.P.+ 2,832 mm (46 mm decrease since 7:00 on June 19)	O.P.+ 2,790 mm (12 mm increase since 7:00 on June 19)
	Water level of Reactor Building	O.P.+ 3,914 mm (8 mm increase since 7:00 on June 19)	O.P.+ 2,940 mm (1 mm increase since 7:00 on June 19)	O.P.+ 2,879 mm (49 mm decrease since 7:00 on June 19)	O.P.+ 2,792 mm (4 mm increase since 7:00 on June 19)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,535 mm (Increase from initial level:5,752 mm, 210 mm increase since 7:00 on June 19) O.P.+ 2,619 mm (Increase from initial level:3,345 mm, 810 mm decrease since 7:00 on June 19) O.P.+ 4,381 mm (Water level from floor:585 mm, No change since 7:00 on June 19)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:40 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:24 on June 19)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 19 to 15:00 on June 19)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:22 on June 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on June 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.