

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 21)**

Water Level of the accumulated water (at 7:00 on June 21)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,471 mm (2 mm decrease since 7:00 on June 20)	O.P.+ 2,412 mm (No change since 7:00 on June 20)	—
	Water level of Turbine Building	O.P.+ 2,621 mm (11 mm increase since 7:00 on June 20)	O.P.+ 2,790 mm (11 mm decrease since 7:00 on June 20)	O.P.+ 2,792 mm (40 mm decrease since 7:00 on June 20)	O.P.+ 2,787 mm (3 mm decrease since 7:00 on June 20)
	Water level of Reactor Building	O.P.+ 3,922 mm (8 mm increase since 7:00 on June 20)	O.P.+ 2,936 mm (4 mm decrease since 7:00 on June 20)	O.P.+ 2,830 mm (49 mm decrease since 7:00 on June 20)	O.P.+ 2,793 mm (1 mm increase since 7:00 on June 20)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,771 mm (Increase from initial level:5,988 mm, 236 mm increase since 7:00 on June 20) O.P.+ 1,901 mm (Increase from initial level:2,627 mm, 718 mm decrease since 7:00 on June 20) O.P.+ 4,383 mm (Water level from floor:587 mm, 2 mm increase since 7:00 on June 20)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 10:40 on June 19)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Currently being transferred (Since 11:24 on June 19)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:22 on June 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on June 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.