

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 22)**

Water Level of the accumulated water (at 7:00 on June 22)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,462 mm (9 mm decrease since 7:00 on June 21)	O.P.+ 2,408 mm (4 mm decrease since 7:00 on June 21)	—
	Water level of Turbine Building	O.P.+ 2,631 mm (10 mm increase since 7:00 on June 21)	O.P.+ 2,766 mm (24 mm decrease since 7:00 on June 21)	O.P.+ 2,826 mm (34 mm increase since 7:00 on June 21)	O.P.+ 2,784 mm (3 mm decrease since 7:00 on June 21)
	Water level of Reactor Building	O.P.+ 3,914 mm (8 mm decrease since 7:00 on June 21)	O.P.+ 2,914 mm (22 mm decrease since 7:00 on June 21)	O.P.+ 2,864 mm (34 mm increase since 7:00 on June 21)	O.P.+ 2,791 mm (2 mm decrease since 7:00 on June 21)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,687 mm (Increase from initial level:5,904 mm, 84 mm decrease since 7:00 on June 21) O.P.+ 1,641 mm (Increase from initial level:2,367 mm, 260 mm decrease since 7:00 on June 21) O.P.+ 4,384 mm (Water level from floor:588 mm, 1 mm increase since 7:00 on June 21)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on June 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 11:24 on June 19 to 10:13 on June 21)	—
		Unit 5 and 6			
		—			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:22 on June 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on June 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.