

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 23)**

Water Level of the accumulated water (at 7:00 on June 23)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,420 mm (42 mm decrease since 7:00 on June 22)	O.P.+ 2,407 mm (1 mm decrease since 7:00 on June 22)	—
	Water level of Turbine Building	O.P.+ 2,642 mm (11 mm increase since 7:00 on June 22)	O.P.+ 2,768 mm (2 mm increase since 7:00 on June 22)	O.P.+ 2,854 mm (28 mm increase since 7:00 on June 22)	O.P.+ 2,794 mm (10 mm increase since 7:00 on June 22)
	Water level of Reactor Building	O.P.+ 3,903 mm (11 mm decrease since 7:00 on June 22)	O.P.+ 2,911 mm (3 mm decrease since 7:00 on June 22)	O.P.+ 2,897 mm (33 mm increase since 7:00 on June 22)	O.P.+ 2,797 mm (6 mm increase since 7:00 on June 22)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,530 mm (Increase from initial level:5,747 mm, 157 mm decrease since 7:00 on June 22) O.P.+ 1,486 mm (Increase from initial level:2,212 mm, 155 mm decrease since 7:00 on June 22) O.P.+ 4,385 mm (Water level from floor:589 mm, 1 mm increase since 7:00 on June 22)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on June 21)	Basement of Unit 3 Turbine Building →Centralized Radiation Waste Treatment Facility (Process Main Building) Transfer Completed (From 11:24 on June 19 to 10:13 on June 21)	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 22 to 15:00 on June 22)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 11:22 on June 19 In operation 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on June 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.