

**Situation of water level, transfer and treatment of the accumulated water
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 24)**

Water Level of the accumulated water (at 7:00 on June 24)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,422 mm (2 mm increase since 7:00 on June 23)	O.P.+ 1,415 mm (992 mm decrease since 7:00 on June 23)	—
	Water level of Turbine Building	O.P.+ 2,652 mm (10 mm increase since 7:00 on June 23)	O.P.+ 2,743 mm (25 mm decrease since 7:00 on June 23)	O.P.+ 2,904 mm (50 mm increase since 7:00 on June 23)	O.P.+ 2,806 mm (12 mm increase since 7:00 on June 23)
	Water level of Reactor Building	O.P.+ 3,910 mm (7 mm increase since 7:00 on June 23)	O.P.+ 2,897 mm (14 mm decrease since 7:00 on June 23)	O.P.+ 2,957 mm (60 mm increase since 7:00 on June 23)	O.P.+ 2,813 mm (16 mm increase since 7:00 on June 23)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,528 mm (Increase from initial level:5,745 mm, 2 mm decrease since 7:00 on June 23) O.P.+ 1,350 mm (Increase from initial level:2,076 mm, 136 mm decrease since 7:00 on June 23) O.P.+ 4,385 mm (Water level from floor:589 mm, No change since 7:00 on June 23)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on June 21)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank	Transfer Completed	(From 10:00 on June 23 to 15:00 on June 23)	
Operation condition of water treatment facility		Cesium Adsorption Apparatus: From 11:22 on June 19 to 8:30 on June 23 Stop 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on June 18 In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.