

**Situation of water level, transfer and treatment of the accumulated water  
in Fukushima Daiichi Nuclear Power Station (at 9:00 on June 25)**

Water Level of the accumulated water (at 7:00 on June 25)		Unit 1	Unit 2	Unit 3	Unit 4
	Water level of Vertical Shaft	Unmeasurable due to drawdown of water level (Less than O.P.+ 850 mm)	O.P.+ 1,422 mm (No change since 7:00 on June 24)	O.P.+ 1,625 mm (210 mm increase since 7:00 on June 24)	—
	Water level of Turbine Building	O.P.+ 2,663 mm (11 mm increase since 7:00 on June 24)	O.P.+ 2,720 mm (23 mm decrease since 7:00 on June 24)	O.P.+ 2,942 mm (38 mm increase since 7:00 on June 24)	O.P.+ 2,819 mm (13 mm increase since 7:00 on June 24)
	Water level of Reactor Building	O.P.+ 3,903 mm (7 mm decrease since 7:00 on June 24)	O.P.+ 2,873 mm (24 mm decrease since 7:00 on June 24)	O.P.+ 3,000 mm (43 mm increase since 7:00 on June 24)	O.P.+ 2,825 mm (12 mm increase since 7:00 on June 24)
	Water level of each building in the Centralized Radiation Waste Treatment Facility	Process Main Building High Temperature Incinerator Building On-site Bunker Building	O.P.+ 4,533 mm (Increase from initial level:5,750 mm, 5 mm increase since 7:00 on June 24) O.P.+ 1,232 mm (Increase from initial level:1,958 mm, 118 mm decrease since 7:00 on June 24) O.P.+ 4,388 mm (Water level from floor:592 mm, 3 mm increase since 7:00 on June 24)		
Situation of transfer of the accumulated water		Unit 1	Unit 2	Unit 3	Unit 4
		—	Basement of Unit 2 Turbine Building →Centralized Radiation Waste Treatment Facility (High Temperature Incinerator Building) Currently being transferred (Since 10:25 on June 21)	—	—
		Unit 5 and 6			
		Basement of Unit 6 Turbine Building →Temporary Tank Transfer Completed (From 10:00 on June 24 to 15:00 on June 24)			
Operation condition of water treatment facility		Cesium Adsorption Apparatus: Since 8:30 on June 23    Suspended 2nd Cesium Adsorption Apparatus (Sarry): Since 16:28 on June 18    In operation Water Desalination Apparatus (reverse osmosis membrane): Intermittent operation depending on the water balance Water Desalination Apparatus (evaporative concentration): Intermittent operation depending on the water balance			
Notes					

※ For quick publication of the data of water level, values are provided as reference values.